

DRAWING LIST

- 00 Isometric
- 01 GF plan
- 02 FF plan
- 03 Loft plan
- 04 Sec A
- 05 Sec B
- 06 Sec C
- 07 Sec D
- 21 Air transfer
- 31 Unit Layout
- 32 Supply Ducts
- 33 Extract Ducts
- 34 Intake Ducts
- 35 Exhaust Ducts

Primary and cross talk attenuation:

Where primary attenuation (1) is represented, please add 100mm onto diameter of ductwork.




Where cross talk attenuation (2) is represented, please add 50mm onto diameter of ductwork.



Intake and Exhaust Insulation

On Intake and Exhaust ducts (leading to outside) we specify double wrap of Armaflex Insulation. Therefore please add 100mm onto the diameter of the ductwork.



green building store
 Green Building Store
 Heath House Mill,
 Heath House Lane,
 Golcar, Huddersfield
 HD7 4JW
 Tel: 01484 461705

Email: mvr@greenbuildingstore.co.uk

DO NOT SCALE
 Retention of Copyright: Environmental Construction Products Ltd retain the copyright of this document. Environmental Construction Products Ltd license the Purchaser to use and copy this document only for the Purchaser's own purposes subject to our Standard Conditions of Sale and to payment of all invoices according to agreed terms

Designer: STEVE CLARKE

Project: 8 BENSON PLACE

Date: 18/09/13 **Scale:** NTS - A3

Detail: 00 - isometric

Preliminary Installation

Job Ref: 183NIC031BENS **C**